

**CERTIFICATE of INSTALLATION**  
**Line-Voltage Track Lighting**

(Page 1 of 3)

**NRCI-ILT-03-E**

PROJECT NAME:	DATE:	Building Permit  Checked by/Date Enforcement Agency Use
PROJECT ADDRESS:		

**GENERAL INFORMATION**

DATE OF BUILDING PERMIT	PERMIT #
-------------------------	----------

BUILDING TYPE	<input type="checkbox"/> Nonresidential	<input type="checkbox"/> High-Rise Residential	<input type="checkbox"/> Hotel/Motel Guest Room
---------------	---	--	---

PHASE OF CONSTRUCTION	<input type="checkbox"/> New Construction	<input type="checkbox"/> Addition	<input type="checkbox"/> Alteration	<input type="checkbox"/> Unconditioned
-----------------------	---	-----------------------------------	-------------------------------------	--

*If more than one person has responsibility for building construction, each person shall prepare and sign an Installation Certificate document applicable to the portion of construction for which they are responsible; alternatively, the person with chief responsibility for construction shall prepare and sign the Installation Certificate document(s) for the entire construction.*

**DECLARATION STATEMENT**

- I certify under penalty of perjury, under the laws of the State of California, the information provided on this form is true and correct.
- I am eligible under Division 3 of the Business and Professions Code to accept responsibility for construction, or an authorized representative of the person responsible for construction (responsible person).
- I certify that the installed features, materials, components, or manufactured devices identified on this certificate (the installation) conforms to all applicable codes and regulations, and the installation is consistent with the plans and specifications approved by the enforcement agency.
- I reviewed a copy of the Certificate of Compliance approved by the enforcement agency that identifies the specific requirements for the installation. I certify that the requirements detailed on the Certificate of Compliance that apply to the installation have been met.
- I will ensure that a completed, signed copy of this Installation Certificate shall be posted, or made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections. I understand that a signed copy of this Installation Certificate is required to be included with the documentation the builder provides to the building owner at occupancy.

Company Name:		
Responsible Person's Name:	Responsible Person's Signature:	
Lic.#	Date Signed:	Position With Company:

**SCOPE OF RESPONSIBILITY**

<i>Enter the date of approval by enforcement agency of the Certificate of Compliance that provides the specifications for the energy efficiency measures for the scope of responsibility for this Installation Certificate:</i>	Date:
---	-------

**Line-Voltage Track Lighting**  
**Certified Integral Current Limiters, and Dedicated Supplementary Overcurrent Protection Panels**

§130.4(b) Before a Line-Voltage Track Lighting Integral Current Limiter or Supplementary Overcurrent Protection Panel will be recognized for compliance with the lighting requirements in Part 6 of Title 24, the person who is eligible under Division 3 of the Business and Professions Code to accept responsibility for the construction or installation of features, materials, components, or manufactured devices shall sign and submit this Installation Certificate.

If any of the following requirements fail the respective Line-Voltage Track Lighting installation test, these methods for determining installed lighting power shall not be used for compliance with Title 24.

*Check all that apply:*

**PART 1 Type of Line-Voltage Track Lighting Control**

**A. Certified Line-Voltage Track Lighting Integral Current Limiter:**

A Line-Voltage Track Lighting Integral Current Limiter that has been certified to the Energy Commission, and consists of a current limiter integral to the end-feed housing of a manufactured line-voltage track lighting system.

**B. Dedicated Line-Voltage Track Lighting Supplementary Overcurrent Protection Panel:**

A Track Lighting Supplementary Overcurrent Protection Panel is a Panelboard containing Supplementary Overcurrent Protection Devices as defined in Article 100 of the California Electric Code, and used only with line voltage track lighting.

**PART 2 Complete this Section for Certified Line-Voltage Track Lighting Integral Current Limiter**

If any of the following requirements fail the track current limiter installation test, this method for determining installed lighting power shall not be used for compliance with Title 24.

- A. The track lighting integral current limiter is certified to the Energy Commission in accordance with Section 110.9 and has been verified by checking the Energy Commission database.
- B. Installed wattage has been determined in accordance with Section 130.0(c)
- C. The track current limiter is used exclusively on the same manufacturer's track for which it is designed
- D. The track current limiter is designed and installed so that the track current limiter housing is permanently attached to the track so that the system will be irreparably damaged if the integral track current limiter housing were to be removed after installation into the track. Methods of attachment may include but are not limited to one-way barbs, rivets, and one-way screws
- E. The track current limiter has identical volt-ampere (VA) rating of the track current limiter, as installed and rated for compliance with Title 24, Part 6, clearly marked on all of the following locations:
  1. So that it is visible for the building officials' field inspection without opening cover-plates, fixtures, or panels, and
  2. Permanently marked on the circuit breaker, and
  3. On a factory-printed label that is permanently affixed to a non-removable base-plate inside the wiring compartment.
- F. The track current limiter employs tamper resistant fasteners for the cover to the wiring compartment.
- G. The track current limiter has a conspicuous factory installed label permanently affixed to the inside of the wiring compartment warning against removing, tampering with, rewiring, or bypassing the device.
- H. Each electrical panel from which track lighting integral current limiters are connected has a factory printed label permanently affixed and prominently located, with the following information:

"NOTICE: Current limiting devices installed in track lighting integral current limiters connected to this panel shall only be replaced with the same or lower amperage. Adding track or replacement of existing current limiters with higher continuous ampere rating will void the track lighting integral current limiter certification, and will require re-submittal and re-certification of California Title 24, Part 6 compliance documentation."
- I. For installations where a total of five or less track current limiters are installed in a single building, all integral track current limiters have be inspected.
- For installations where a total of more than five track current limiters are installed in a single building, no less than five track current limiters have be inspected, up to five inspections for each 20 installed track current limiters.

**PART 3 Complete this Section for Dedicated Line-Voltage Track Lighting Supplementary Overcurrent Protection Panels**

If any of the following requirements fail the Dedicated Line-Voltage Track Lighting Supplementary Overcurrent Protection Panel installation test, this method shall not be used for determining installed lighting power. Note that the Line-Voltage Track Lighting Supplementary Overcurrent Protection Panels are not required to be certified to the Energy Commission.

- A. Installed wattage has been determined in accordance with Section 130.0(c)
- B. The Dedicated Line-Voltage Track Lighting Supplementary Overcurrent Protection Panels is Listed in accordance with Article 100 of the California Electric Code
- C. The Dedicated Line-Voltage Track Lighting Supplementary Overcurrent Protection Panels is used only for line-voltage track lighting.
- D. No Supplementary Overcurrent Protection Panels been used to determine installed wattage for any lighting system other than line-voltage track lighting.
- E. No other lighting or building power is connected to a Supplementary Overcurrent Protection Panel
- F. The Dedicated Line-Voltage Track Lighting Supplementary Overcurrent Protection Panels is installed in an electrical equipment room, or permanently installed adjacent to the lighting panel board providing supplementary overcurrent protection for the track lighting circuits served by the supplementary over current protection pane
- G. There is a prominently labeled permanently attached to the panel by the manufacturer with the following information:

"NOTICE: This Panel for Track Lighting Energy Code Compliance Only. The overcurrent protection devices in this panel shall only be replaced with the same or lower amperage. No other overcurrent protective device have been added to this panel. Adding to, or replacement of existing overcurrent protective device(s) with higher continuous ampere rating, will void the panel listing and require re-submittal and re-certification of California Title 24, Part 6 compliance documentation."